




**NOTES:**

1. Specific site conditions may require an increase in the concrete encasement dimensions and/or reinforcement. It is the customer's responsibility to ensure the concrete encasement is designed for the application. A minimum concrete strength of 25MPa is recommended. The concrete should be vibrated to eliminate air pockets. *Engineering advice may be required.*
2. The finished level of the pavers must be approximately 3mm above the top of the channel edge.
3. The paver course adjacent to the channel edge must be fully bonded to the concrete encasement.
4. For further details, refer to ACO's design & site installation files at [www.acodrain.com.au/resources](http://www.acodrain.com.au/resources).

**SPECIFICATION CLAUSE  
KLASSIKDRAIN KS200 - LOAD CLASS A-B**

**GENERAL**

THE SURFACE DRAINAGE SYSTEM SHALL BE ACO'S KLASSIKDRAIN KS200 POLYMER CONCRETE V-PROFILE CHANNEL SYSTEM WITH STAINLESS STEEL EDGE RAILS AS MANUFACTURED BY ACO.

**MATERIALS**

KS200 CHANNELS SHALL BE MANUFACTURED FROM POLYESTER RESIN POLYMER CONCRETE WITH AN INTEGRALLY CAST-IN STAINLESS STEEL EDGE RAIL. PROPERTIES OF POLYMER CONCRETE WILL BE AS FOLLOWS WITH SUPPORTING DOCUMENTATION:

|                                       |                                        |
|---------------------------------------|----------------------------------------|
| COMPRESSIVE STRENGTH:                 | 98 MPa                                 |
| FLEXURAL STRENGTH:                    | 26 MPa                                 |
| TENSILE STRENGTH:                     | 14 MPa                                 |
| WATER ABSORPTION:                     | 0.07%                                  |
| FROST PROOF:                          | YES                                    |
| COEFFICIENT OF EXPANSION/CONTRACTION: | $2.02 \times 10^{-5}/^{\circ}\text{C}$ |
| WATER VAPOUR TRANSMISSION:            | 0.0364g/m <sup>2</sup>                 |
| NON FLAMMABLE:                        | YES                                    |
| COEFFICIENT OF ROUGHNESS (MANNINGS):  | n=0.011                                |
| RESISTANT TO WEATHERING:              | YES                                    |
| DILUTE ACID AND ALKALI RESISTANT:     | YES                                    |
| SF SEALANT GROOVE                     | YES                                    |

**CHANNELS**

KS200 CHANNEL SHALL BE 200mm NOMINAL INTERNAL WIDTH WITH AN OVERALL WIDTH OF 260mm. CHANNEL INVERT SHALL HAVE A V-PROFILE TO ALLOW EFFICIENT DRAINAGE. KS200 SLOPED CHANNELS SHALL HAVE A BUILT-IN SLOPE OF 0.5%. ALL CHANNELS SHALL BE INTERLOCKING WITH A MALE/FEMALE JOINT.

**GRATES**

INSERT SPECIFICATION FOR THE SELECTED GRATE. REFER TO THE RELEVANT ACO SPECIFICATION INFORMATION SHEET, CLICK [www.acodrain.com.au/resources](http://www.acodrain.com.au/resources).

**INSTALLATION**

THE COMPLETE DRAINAGE SYSTEM SHALL BE BY ACO AND TO BE INSTALLED FOR ITS INTENDED PURPOSE. ANY DEVIATION OR PARTIAL USE OF THE SPECIFIED SYSTEM AND/OR IMPROPER INSTALLATION WILL VOID ALL WARRANTIES PROVIDED BY ACO.

KS2-AB-P1



DATE: 03/14

**KS200 - KLASSIKDRAIN - LOAD CLASS: A-B  
FOR PAVERS**

**INSTALLATION DRAWING - ACO DRAIN**

ACO Limited  
New Zealand  
Ph: 0800 448 080  
[www.askaco.nz/aco-drain](http://www.askaco.nz/aco-drain)

Start Your  
Specification  
Here

