



NOTES:

1. Specific site conditions may require an increase in these dimensions or reinforcement. It is the customer's responsibility to ensure the installation drawing is detailed for the application and pit structure is protected from undue stress. *Engineering advice may be required.*
2. The finished level of the pavers must be flush with the top of the pit.
3. The paver course adjacent to the pit edge must be fully bonded to the sand & cement.
4. Refer to ACO's latest installation instructions for complete details.

The cable enclosure(s) (for a nominal wheel load of 2670kg) with a *clear opening(s)* of shall be **ACO** Polyethylene Plastic Pit(s) Type (s) and part no.(s) with Steel / **PowerLok®** lid(s) and part no.(s)

All materials and components within the scope of the system shall be obtained from ACO and the work shall be carried out as specified in accordance with the manufacturer installation recommendations.